

WELL COMPLETION REPORT (Please complete in black ink or type.)

PERMIT #: N/A CUPWMUP#: _____ DID#: _____

Indicate the number of wells drilled/abandoned for this report: _____
 Indicate the number of wells permitted but not drilled/abandoned that are being cancelled: _____

WATER WELL CONTRACTOR'S SIGNATURE David Muffett License # Q236

I certify that the information provided in this report is accurate and true.

GROUT	No. of Bags	From (ft.)	To (ft.)
Neat Cement:			
Bentonite:	8	0	53
(Other)			

WELL LOCATION: County Marion


Latitude: _____ 1/4 of _____ 1/4 of Section _____, Township _____, Range _____, Longitude: _____

DATE STAMP

Official Use Only

CHEMICAL ANALYSIS WHEN REQUIRED
 Iron: _____ ppm Sulfate: _____ ppm
 Chlorides: _____ ppm TDS _____ mg/l
 Conductivity _____ umhos/cm

[] Lab Test [] Field Test Kit
 Pump Type
 [] Centrifugal [] Jet [] Submersible [] Turbine
 Horsepower: _____ Capacity: _____ GPM: _____
 Pump Depth: _____ ft. Intake Depth: _____ ft.
 Form LEG-R-005.00(10/05)



OWNER'S NAME: City of Ocala 10" drainage
 COMPLETION DATE: 8/13/19 Florida Unique I.D.: _____ well
 Parcel # (Pin): _____ NE Watula Ave
 WELL USE: _____

[] Public Supply [] Irrigation [] Domestic [] Monitor
 [] Injection [X] Other

DRILL METHOD:
 [] Rotary [] Cable Tool [X] Combination
 [] Jet [] Auger [] Other _____

Measured Static Water Level: 22 Measured Pumping Water Level: _____
 After _____ Hours at _____ GPM, Measuring Pt. (Describe): _____
 Which is _____ ft. [] above [] below land surface
 Casing: [X] Black Steel [] Galvanized [] PVC [] Other: _____

Casing Diameter and Depth (ft.)	Depth (feet)		DRILL CUTTINGS LOG Examine cuttings every 20 ft. or at formation changes. Note cavities, depth to producing zones.
	From	To	
Diameter: <u>10"</u> From: <u>0</u> To: <u>53</u>	0	6	Brown Med. Sand
Diameter: _____ From: _____ To: _____	6	15	Brown Sandy Clay
Diameter: _____ From: _____ To: _____	15	28	Gray Sandy Clay
Diameter: _____ From: _____ To: _____	28	32	White Lime med
Diameter: _____ From: _____ To: _____	32	48	Gray Sandy Clay
Diameter: _____ From: _____ To: _____	48	55	White Lime hard
Diameter: _____ From: _____ To: _____	55	70	Gray Lime med
Liner [] or Casing [] Diameter: _____ From: _____ To: _____	70	90	White Lime med
	90	105	Gray Lime med
	105	110	White Lime med
	110	125	Gray Lime med
	125	145	tan Lime med
	145	150	tan Lime hard
	150	160	tan Lime med

Driller's Name (print or type):

David Muffett

WELL COMPLETION REPORT (Please complete in black ink or type.)

PERMIT #: N/A CUPWUP#: _____ DID#: _____

Indicate the number of wells drilled/abandoned for this report: _____
 Indicate the number of wells permitted but not drilled/abandoned that are being cancelled: _____

WATER WELL CONTRACTORS
 SIGNATURE David Muffett License # 9236

I certify that the information provided in this report is accurate and true.

GROUT	No. of Bags	From (ft.)	To (ft.)
Neat Cement:			
Bentonite:	9	0	63
(Other)			

WELL LOCATION: County _____
 1/4 of _____ 1/4 of Section _____, Township _____, Range _____
 Latitude: _____, Longitude: _____

DATE STAMP _____


Official Use Only

CHEMICAL ANALYSIS WHEN REQUIRED
 Iron: _____ ppm Sulfate: _____ ppm
 Chlorides: _____ ppm TDS _____ mg/l
 Conductivity _____ umhos/cm

Lab Test Field Test Kit

Pump Type
 Centrifugal Jet Submersible Turbine
 Horsepower: _____ Capacity: _____ GPM: _____
 Pump Depth: _____ ft. Intake Depth: _____ ft.

Form LEG-R.005.00(10/05)



OWNER'S NAME: City of Ocala 12" Drainage Well # 2
 COMPLETION DATE: 8/15/19 (NEG) Florida Unique I.D.: _____
 Parcel # (Pin): _____
 WELL USE: _____

Public Supply Irrigation Domestic Monitor
 Injection Other Drainage

DRILL METHOD:
 Rotary Cable Tool Combination
 Jet Auger Other _____

Measured Static Water Level: 16 Measured Pumping Water Level: _____
 After _____ Hours at _____ GPM. Measuring Pt. (Describe): _____
 Which is _____ ft. above below land surface
 Casing: Black Steel Galvanized PVC Other: _____

Casing Diameter and Depth (ft.)	Depth (feet)		DRILL CUTTINGS LOG Examine cuttings every 20 ft. or at formation changes. Note cavities, depth to producing zones. Color Grain Size Type of Material
	From	To	
Diameter: <u>12</u> From: <u>0</u> To: <u>63</u>	0	8	Brown sand med
Diameter: _____ From: _____ To: _____	8	16	Tan sandy clay
Diameter: _____ From: _____ To: _____	16	30	Gray Sandy Clay
Diameter: _____ From: _____ To: _____	30	35	White Lime med
Diameter: _____ From: _____ To: _____	35	40	Gray Sandy Clay
Diameter: _____ From: _____ To: _____	40	61	White Lime med
Liner <input type="checkbox"/> or Casing <input type="checkbox"/> Diameter: _____ From: _____ To: _____	61	64	White lime hard
	64	75	White Lime med
	75	100	Gray tan Lime med
	100	115	VOFD
	115	120	Gray Tan Lime

Driller's Name (print or type): David Muffett

WELL COMPLETION REPORT (Please complete in black ink or type.)

PERMIT #: N/A CUP/WUP#: _____ DID#: _____

Indicate the number of wells drilled/abandoned for this report: _____
 Indicate the number of wells permitted but not drilled/abandoned that are being cancelled: _____

WATER WELL CONTRACTOR'S SIGNATURE

David Muffett License # 9236


I certify that the information provided in this report is accurate and true.

GROUT	No. of Bags	From (ft.)	To (ft.)
Neat Cement:			
Bentonite:	11	0	72'
(Other)			

WELL LOCATION: County _____

1/4 of _____ 1/4 of Section _____, Township _____, Range _____
 Latitude: _____, Longitude: _____

DATE STAMP _____
 Official Use Only



CHEMICAL ANALYSIS WHEN REQUIRED
 Iron: _____ ppm Sulfate: _____ ppm
 Chlorides: _____ ppm TDS _____ mg/l
 Conductivity _____ umhos/cm
 Lab Test Field Test Kit
 Pump Type
 Centrifugal Jet Submersible Turbine
 Horsepower: _____ Capacity: _____ GPM: _____
 Pump Depth: _____ ft. Intake Depth: _____ ft.
 Form LEG-R.005.00(10/05)

OWNER'S NAME: City of Ocala 12" Drainage Well
 COMPLETION DATE: _____ Florida Unique I.D.: _____ #33
 Parcel # (Pin): _____ (NE10)
 WELL USE: _____

Public Supply Irrigation Domestic Monitor
 Injection Other Drainage

DRILL METHOD:
 Rotary Cable Tool Combination
 Jet Auger Other _____

Measured Static Water Level: 26 Measured Pumping Water Level: _____
 After _____ Hours at _____ GPM, Measuring Pt. (Describe): _____
 Which is _____ ft. above below land surface
 Casing: Black Steel Galvanized PVC Other: _____

Casing Diameter and Depth (ft.)	Depth (feet)		DRILL CUTTINGS LOG Examine cuttings every 20 ft. or at formation changes. Note cavities, depth to producing zones. Color Grain Size Type of Material
	From	To	
Diameter: <u>12"</u> From: <u>0</u> To: <u>72'</u>	0	2	Brown sand med
Diameter: _____ From: _____ To: _____	2	25	Tan sandy clay
Diameter: _____ From: _____ To: _____	25	38	Red sandy clay
Diameter: _____ From: _____ To: _____	38	72	White lime soft
Diameter: _____ From: _____ To: _____	72	85	White lime med
Diameter: _____ From: _____ To: _____	85	110	Tan lime med
Liner <input type="checkbox"/> or Casing <input type="checkbox"/> Diameter: _____ From: _____ To: _____	110	120	Tan Lime hard
Diameter: _____ From: _____ To: _____	120	180	Tan Lime med

Driller's Name (print or type): David Muffett